



MUNICIPAL CORPORATION CHANDIGARH
Public Health Laboratory at Water Works Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GMSSS/27-C/2023/478 Dated 31.05.2023
 Issued to :- The Principal,
 Govt. Model Sr. Sec. School,
 Sector - 27 - C, Chandigarh.
 Quantity of sample :- Approximate 1200 ml.
 Date of Collection :- 01.06.2023
 Client reference :- Sample collected by Laboratory Staff.
 Packing of sample :- Sample filled in P.P. and Glass Bottle.
 Source of sample :- from School Tap of Govt. Model Sr. Sec. School,
 Sector - 27 - C, Chandigarh.


S. No. Examination	Quality Standard	Units	Results
1. Turbidity	<1.0	N.T.U	0.9
2. pH	7.0-8.5	----	7.78
3. Residual Chlorine	0.2 - 0.4	mg/L.	0.2
4. Total Alkalinity (as CaCO ₃)	200	-do-	90
5. Total Hardness (as CaCO ₃)	200	-do-	76
6. Chlorides (as Cl)	200	-do-	04
7. Free & Saline Ammonia	Nil	-do-	.NIL.
8. Total Dissolved Solids	500	-do-	135
9. M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.05 /2023-24/137865, dated 31.05.2023, Amount Rs.3300/-

Note:- **Water is fit for drinking.**

Lab. No. MCPHL/23/ 2367


Dated:- 03.06.2023



Chemist.
MCPH Laboratory
Chandigarh


Sub Divisional Engineer.
M.C.P.H. Sub Division No.1,
Chandigarh.
Dated:-

Endst No. MCPHL/23/ _____

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for info please.


Chemist.
MCPH Laboratory
Chandigarh


Sub Divisional Engineer.
M.C.P.H. Sub Division No. 1,
Chandigarh.